

Executive Engineer
South Zone(Udhana)



Surat Municipal Corporation
South Zone(Udhana)
Opp. Satyanagar, Udhana,
Surat.

☎ 2277043, 2278429.

QUOTATION INQUIRY

SZ/Tech./No.4413
Dtd.: - 28/07/2021

TO,

Sub: - Offer for Renovation/rewiring of LT panel, supply and retrofitting of 250A MCCB and associated work at Udhna Zone Office, SMC Surat.

Dear Sir,

South Zone of Surat municipal corporation is inviting quotation for the work of Offer for Renovation/rewiring of LT panel, supply and retrofitting of 250A MCCB and associated work at Udhna Zone Office, SMC Surat.

Send your offer in a sealed cover So as to reach in the office of Executive Engineer [South Zone-Udhna] on or before Dt.06/08/2021 6.00 up to pm. Please note that the sealed cover shall be super scribed with the name of work. Details of material required is as following.

Quotation

Sr. No	Item	Qty	Unit	Rate per Unit	Total
1	Maintanance/Rewiring of LT Panel, Detailed Scope of work is mentioned elsewhere in document.	1	Job		
2	Supply and retrofitting of 250A 4P 25kA microprocessor based MCCB	1	Nos.		
3	SITC of 3.5C x 70 sqmm Alu. armoured XLPE Cable Laying with 65 mm ID DWC pipe & including Excavation	80	Mtr.		
4	SITC of 3.5C x 50 sqmm Alu. armoured XLPE Cable Laying with 65 mm ID DWC pipe & including Excavation	85	Mtr.		
5	Electrical Rubber insulation Mat suitable for LT Panel (dimension 2 mtr x 1 mtr)	2	Nos.		
6	SITC of Chemical Earthing rod System with rod of length 3 mtr. for LT Panel & DG Set	3	Nos.		
7	Providing and erecting G.I. strip of 25 x 3 mm size earthing of LT panel board, DG Set using proper clamp.	60	Kg		
8	Digital Multifunctional Meter	2	Nos		
Total Amount with GST					

Scope of Work

1. Cleaning of All feeders of LT Panel.
2. Tightning of Power & Control cable Terminals of all feeders of LT Panel in all respect.
3. Tightning of Busbar Joints & Terminals of all feeders of LT Panel in all respect.
4. Replacment of existing SFU with 250 Amp., 4P, 25KA microprocessor based MCCB. (mentioned in Sr. No.02) MCCB shall be operatable from door with rotating handle with door interlock. All necessary arrangements for retrofitting & housing of MCCB will be in the scope of Contractor must consider the same while quoting rates.
5. Identification & removed unused cables .

☐ Terms/conditions of quotation ☐

* Work Completion Period of entire work : -	30 Days
* All Taxes/Duties,GST,Octroi etc.: -	Included.
* FOR: -	Offer for Renovation/rewiring of LT panel, supply and retrofitting of 250A MCCB and associated work at Udhna Zone Office, SMC Surat
* Validity of quotation: -	120 Days
* Payment condition: -	Payment shall be made within 20 days after safe receipt, inspection/ testing and commissioning of material.
* Note:-	Catalouge of offered make must be attached with Quotation. Bidders can not quote any items with other Makes mentioned in above quotation.
* Make	For Cable @ Finolex, RR Kabel, KEI, Havells For MCCB @ L&T, C&S, Hager, Schnider, Siemens For Other @ ISI mark

- Electrical Material like Cable,MCCB, Multi function meter must have warranty minimum 1 year.
- Quantity mentioned here are approximate only. It may vary as per actual requirement.
- SMC will not pay any transportation charges and also not provide any type of assistance whice carrying out above mention work. All accessories needed in installation of above mentioned items are in bidders scope only.
- Bidders are suggested to visit the site location before quoting this quotation and for any further query, bidder can contact Light department of South Zone, SMC.
- Successfull Contractor have to do Agreement, Surety & Undertaking on the non judicial stamp paper of Rs.300/- each purchased from Surat city only.
- Successful Contractor shall deposite Security Deposite of 2.5% of amount of Workorder within 10 days from work order date. If Contractor fails to deposit same, penalty at 0.065% of SD amount per day will be levied.
- The rates should be inclusive of all taxes/ duties, GST and Octroi. Fulfillments of this condition are must or else the quotation shall be liable for outright rejection.
- The name of work i.e." Quotation for the work of" must be mentioned on the envelope without which quotation is likely to be rejected, which must be noted.

Thanking You,

Sd/-
Executive Engineer
South Zone (Udhna)
Surat Municipal Corporation.

* SIGNATURE & SEAL OF CONTRACTOR *