

SURAT MUNICIPAL CORPORATION

M. D. Chavda
Executive Engineer
South - West (Athwa) Zone



Phone : 0261-2663049, 2663050
Fax : 0261-2668426

No. S.W.(Athwa) Zone / Out./3681
Date : 13/09/2021

To,

.....
.....
.....
.....

Sub : SITC of Fire Alarm System with necessary accessories within service area of
PDU Indoor Stadium, Surat.

Sealed quotation duly super scribed and returnable on or before 30/09/2021 (before 5 PM) to the office of "Executive Engineer, South - West (Athwa) Zone, Adarsh Soc., Athwalines, Surat" is invited to carry out the work as mentioned in attached sheet with terms & conditions as mentioned below :

- 1) The bidder shall visit the site and gather information before quoting rates.
- 2) Defect liability period for the product shall be of One year's onsite warranty.
- 3) Commissioner, SMC shall be final authority for decision at the time of dispute, if any.
- 4) SMC reserves every right to increase/decrease in scope of work and/or eliminate quantity or terminate the work any time without prior notice.
- 5) Quotation once submitted shall not be withdrawn.
- 6) Quotation once accepted shall be binding to the bidder.
- 7) Rate should be including of all but except GST. Rate applicable for GST shall be mentioned separately with HSN code.
- 8) Time Limit to complete the work shall be 30 days.
- 9) Payment shall be made within at least 30 days from the completion of work and producing retail invoice.
- 10) The offer shall be submitted with Earnest Money Deposit Rs. 2000/- in the form of Demand Draft or Pay Order or Banker's Cheque in favor of SURAT MUNICIPAL COPRPORATION, payable at Surat. Offer without EMD shall not be considered.
- 11) SMC reserves its right to accept or reject any quotation without giving any reason.
- 12) Successful bidder shall have to submit 2 % of quoted Amount as a security deposit & also enter into agreement on 3 nos. of Rs. 300/- Stamp Paper.
- 13) Entire System Shall have to be certified by chief fire officer of Surat Municipal Corporation and necessary NOC shall have to be obtained.
- 14) All material Testing reports shall have to be submitted.
- 15) Offer should be in the form of percentage above or below or at par of estimated value mentioned in annexure. No additional papers or alternate offer or conditions shall be attached with quotation.

Signature & Seal of the contractor
Mobile Number :

Sd/-
Executive Engineer
South - West (Athwa) Zone
Surat Municipal Corporation

SURAT MUNICIPAL CORPORATION

South West (Athwa) Zone

Pandit Dindayal Upadhyay Indoor Stadium

Schedule B

Name of Work : SITC of Addressable Alarm System within Service Area of PDU Indoor Stadium, located at Athwalines, Surat

No	Item Description	Qty	Unit	Rate / Unit (Rs)	Amount (Rs)
1	2	3	4	5	6
1	SITC of 1 Loop Micro processor based 2 wire fault tolerant loop, (each loop accessing 99 detectors and 99 modules) Networkable Fire Alarm / Detection Control Panel . The panel shall be able to give location of all fire/fault conditions of addressable units via the address codes. Further, the panel must be able to automatically switch ON /OFF respective control module when ever any alarm is triggered. The panel shall have rectifier, Loop cards, 2x40 – Character LCD alphanumeric display with back-light to indicate Fire/Fault Signal with address and analog output, external/inbuilt printer to log all fire or fault events complete in all respects. The panel should be networkable for up to 99 panels. The Panel Shall be Sheet Steel Painted, sealed to IP30. The Panel Shall have 20 Zones with Individual LED Indicators, expandable to 80 LED Indicators. The Panel Shall have 3 Serial Ports. The panel shall have provision to integrate with PA System and shall have provision to connect to Building Management system through Modbus Card. The panel shall have a 2 programmable sounder outputs, and open / short circuit monitoring. The panel shall have a built in power supply and battery charger, which should be capable to charge maintenance free 24 AH, 2x12 volt SMF lead acid batteries capable of running for a minimum of 24 hours with battery charger complete as required & confirming to BS5839 standards.	01	No	85685.00	85685.00

2	SITC of Intelligent Analog Addressable Type Photoelectric Type Smoke Detector Complete with Dual LED, Hard Addressable Having rotary decade Address switches from 01-99, complete with Mounting Base and required mounting accessories Complete as required Conforming to BS 5839 Standards and Duly Approved by EN54/LPCB Make: BOSCH/HONEYWELL/SYSTEM SENSOR only	12	No	1760.00	21120.00
3	SITC of Intelligent Analog Addressable Type Manual Call Point having Surface or flush mounting Option fully complaint to EN54 having Rotary Decade Switches for Addressing from 01-99 complete with Back Box for Mounting Complete as required conforming to BS5839 Standards and Duly Approved by EN54/LPCB Make: BOSCH/HONEYWELL/SYSTEM SENSOR only	02	No	2786.00	5572.00
4	SITC of Addressable Type Loop Powered Hooter Cum Strobe complete with 32 tone selection, volume setting features, IP24 housing, Wide operating voltage range, complete with Mounting Base with required mounting accessories as required conforming to BS5839 Standards and Duly Approved by EN54/LPCB Make: BOSCH/HONEYWELL/SYSTEM SENSOR only	02	No	6892.00	13784.00
5	Supply & Laying of 1.1 KV grade, 2 core, 1.50 sq.mm. stranded copper conductor , ISI marked , PVC insulated, PVC sheathed, Aluminum miler tape shielded FRLS wire. Make: Polycab/Finolex/RR only	500	Mtr	75.00	37500.00
(a)	Total				163661.00
(b)	Percentage above / below / at par (+/-/0)				
(c)	Bidder's Total (a + b)				
(d)	GST Rate (SGST+CGST)				
(e)	Grand Total (c + d), In Figures				
In Words,					

SIGNATURE AND SEAL OF THE CONTRACTOR :
NAME AND ADDRESS :
DATE :

Sd/-
Executive Engineer
South West (Athwa) Zone
SMC